



# City of Bloomington Fire Department

PO Box 100  
Bloomington Indiana 47402  
812-332-9763

Mayor Kerry Thomson

Fire Chief Roger Kerr

## Fire Inspection

Current Date	Inspected by	Inspection Number	Completed at
05/03/2024	Chuck Edward Cohenour	BFD-2024-0001791	05/03/2024 12:52:00

Business Name	Address	City	State	Zip
Blooming labs	1840 S WALNUT ST	BLOOMINGTON	IN	47401
		Suite #200		

### Fire Inspection Results

#### Exterior:

**ITEM:** Is this Building Occupied

**RESULT:** Yes

#### Systems:

**✘ Fail**

**ITEM:** Fire Extinguishers

**CODE:** NFPA 10 - 6 - Maintenance - 6.3.1 - 6.3.1 - Section 6.3\* Maintenance. - Section 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydro static test, or when specifically indicated by an inspection or electronic notification.

#### Additional Comments:

**ITEM:** Any additional comments

**RESULT:** No

---

**Ad-hoc violations:**

**✘ Fail**

**ITEM:** Covers over electrical outlets in lounge.

**CODE:** Indiana Fire Code - 605.1 - Abatement of electrical hazards. - Identified electrical hazards shall be abated. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used.

---



Put covers over electrical boxes and ceiling and lab.

---

**✘ Fail**

**ITEM:** Put ceiling tiles back in track

**CODE:** Indiana Fire Code - 315.3.1 - Ceiling clearance. - Storage shall be maintained 2 feet (610 mm) or more below the ceiling in nonsprinklered areas of buildings or a minimum of 18 inches (457 mm) below sprinkler head deflectors in sprinklered areas of buildings. Exception: Sidewall storage to a maximum depth of thirty (30) inches (seventy-six and two -tenths (76.2) centimeters) shall be acceptable to the ceiling in non-sprinklered buildings.

---



Put ceiling tiles and light back in tracks

---

Re-Inspection scheduled to be conducted on or after 06/07/2024.

# Inspection Signatures

Occupancy Contact Signature

M Webb

---

Mark Webb  
Manager  
MLRE4@aol.com

Inspector Signature

CEC II

---

Chuck Edward Cohenour  
Deputy Fire Marshal  
812-369-2201  
charles.cohenour@bloomington.in.gov